

May 05, 2020

Corrigendum – 05

Sub: Clarifications on UPS Queries and Extension of date for participating in the e-tender

E-Tender Reference No.	EXIM/RFP/2019-20/083
E-Tender For:	Data Centre Design and Construction for Export-Import Bank of India

With reference to queries received by bidder regarding UPS system, the clarifications by the Bank are as follows:

1) Sr. no 3.2.1- UPS system:

Point 1- UPS rectifier can be considered - SCR / IGBT (technology should have been in for the last 3 years).

Point 2- Isolation transformer can be considered as - Internal or External type.

2) No further queries will be accepted beyond this point of time as we have already given ample time from the date of the pre-bid meeting.

The revised schedule is as follows:

Last date for acceptance of E-Tender Document Cost, IP Agreement	May 29,2020 4:00 PM
Document Downloading End Date	May 29,2020 4:00 PM
Last Date and Time For E-Tender Submission	May 30,2020 4:00 PM
Opening of Tender	June 01,2020 4:00 PM